

## Attachment L - Results Summary Lead in Water Sample

School Name: **Bryant Elementary School**

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
1WF	38-0513-B01	WF between Rms 1 & 2	8.17	No
2WF	38-0513-B02	WF next to Rm 7	6.63	No
3WF	38-0513-B03	WF outside of custodial room	9.96	No
4WF	38-0513-B04	WF outside cafeteria	ND	No
5WF	38-0513-B05	WF inside nurse's office	2.84	No
6S	38-0513-B06	Sink inside kitchen cafeteria	ND	No
7WF	38-0513-B07	WF next to Rm 29	14.2	No
8WF	38-0513-B08	WF/Filler Station next to rm 31 (filler)	ND	No
9WF	38-0513-B09	WF/Filler Station next to rm 31 (bubbler)	ND	No
10S	38-0513-B10	Faculty Lounge sink	1.33	No
-	38-1513-B11	Deionized blank		

Action Level (AL) ≥15.5 parts per billion (ppb)



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

5/30/2017

Phone: (856) 616-9516

Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/16/2017. The results are tabulated on the attached data pages for the following client designated project:

**Project ID: Teaneck BOE**  
**Bryant ES / PR-170213-0991**

The reference number for these samples is EMSL Order #011703816. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011703816  
 CustomerID: EDI50  
 CustomerPO:  
 ProjectID: Teaneck BOE

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 05/16/17 11:25 AM

Project: **Bryant ES / PR-170213-0991**

**Analytical Results**

<i>Client Sample Description</i>		<i>Collected:</i>	<i>5/13/2017</i>	<i>Lab ID:</i>	<i>011703816-0001</i>			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	8.17	1.00	µg/L	5/18/2017	EG	5/18/2017	EG
<i>Client Sample Description</i>		<i>Collected:</i>	<i>5/13/2017</i>	<i>Lab ID:</i>	<i>011703816-0002</i>			
38-0513-B02 Water Fountain Next to Rm 7								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	6.63	1.00	µg/L	5/18/2017	EG	5/18/2017	EG
<i>Client Sample Description</i>		<i>Collected:</i>	<i>5/13/2017</i>	<i>Lab ID:</i>	<i>011703816-0003</i>			
38-0513-B03 Water Fountain Outside of Custodial Room								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	9.96	1.00	µg/L	5/18/2017	EG	5/18/2017	EG
<i>Client Sample Description</i>		<i>Collected:</i>	<i>5/13/2017</i>	<i>Lab ID:</i>	<i>011703816-0004</i>			
38-0513-B04 Water Fountain Outside Cafeteria								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	5/18/2017	EG	5/18/2017	EG
<i>Client Sample Description</i>		<i>Collected:</i>	<i>5/13/2017</i>	<i>Lab ID:</i>	<i>011703816-0005</i>			
38-0513-B05 Water Fountain Inside Nurse's Office								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	2.84	1.00	µg/L	5/18/2017	EG	5/18/2017	EG
<i>Client Sample Description</i>		<i>Collected:</i>	<i>5/13/2017</i>	<i>Lab ID:</i>	<i>011703816-0006</i>			
38-0513-B06 Sink Inside Kitchen Cafeteria								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	5/18/2017	EG	5/18/2017	EG
<i>Client Sample Description</i>		<i>Collected:</i>	<i>5/13/2017</i>	<i>Lab ID:</i>	<i>011703816-0007</i>			
38-0513-B07 Water Fountain Next to Rm 29								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	14.2	1.00	µg/L	5/18/2017	EG	5/18/2017	EG
<i>Client Sample Description</i>		<i>Collected:</i>	<i>5/13/2017</i>	<i>Lab ID:</i>	<i>011703816-0008</i>			
38-0513-B08 Water Fountain / Filler Station Next to Rm 31 (Filler)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011703816

CustomerID: EDI50

CustomerPO:

ProjectID: Teaneck BOE

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 05/16/17 11:25 AM

Project: **Bryant ES / PR-170213-0991****Analytical Results**

**Client Sample Description** 38-0513-B08 **Collected:** 5/13/2017 **Lab ID:** 011703816-0008  
 Water Fountain / Filler Station Next to Rm  
 31 (Filler)

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	5/18/2017	EG	5/18/2017	EG

**Client Sample Description** 38-0513-B09 **Collected:** 5/13/2017 **Lab ID:** 011703816-0009  
 Water Fountain / Filler Station Next to Rm  
 31 (Bubbler)

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	5/18/2017	EG	5/18/2017	EG

**Client Sample Description** 38-0513-B10 **Collected:** 5/13/2017 **Lab ID:** 011703816-0010  
 Faculty Lounge Sink

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.33	1.00	µg/L	5/22/2017	EG	5/22/2017	EG

**Client Sample Description** 38-0513-B11 **Collected:** 5/13/2017 **Lab ID:** 011703816-0011  
 Deionized Blank

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	5/22/2017	EG	5/22/2017	EG

**Definitions:**

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)