

## Attachment L - Results Summary Lead in Water Sample

School Name: Central Administrative Offices

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
01S	58-0609-01	Kitchenette Sink	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)





**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

6/21/2021

Phone: (856) 616-9516

Fax: (586) 616-9517

DEC 15 2021

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 6/10/2021. The results are tabulated on the attached data pages for the following client designated project:

**Project ID: Teaneck BOE**  
**Teaneck BOE - Admin Bldg, PR-210416-1683**

The reference number for these samples is EMSL Order #012106213. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012106213  
 CustomerID: EDI50  
 CustomerPO:  
 ProjectID: Teaneck BOE

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 6/10/2021 12:30 PM

Project: Teaneck BOE - Admin Bldg, PR-210416-1683

**Analytical Results**

*Client Sample Description* 58-0609-01 *Collected:* 6/9/2021 *Lab ID:* 012106213-0001  
 Kitchenette Sink

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>		<i>Analysis Date &amp; Analyst</i>	
<b>METALS</b>							
200.8	Lead	ND	1.00 µg/L	6/18/2021	VD	6/18/2021	VD
						18:33	

*Client Sample Description* 58-0609-02 *Collected:* 6/9/2021 *Lab ID:* 012106213-0002  
 DI Water Blank

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>		<i>Analysis Date &amp; Analyst</i>	
<b>METALS</b>							
200.8	Lead	ND	1.00 µg/L	6/18/2021	VD	6/18/2021	VD
						18:37	

**Definitions:**

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results