



Environmental Design Inc.

Professional Environmental Consultants

Lead (Pb) in Water Sampling Chain of Custody

EMSL Order ID (Lab Use Only): 012207276

| | | | |
|-----------------------------|------------------------------------|--------------------------|----------------------------------------------------------------------------------------------------------------------|
| Company: | Environmental Design Inc. (EDI-50) | EMSL Bill To: | EDI-50 |
| Street: | 5434 King Avenue, Suite 101 | Phone: | 856-616-9516 |
| City/State/Zip: | Pennsauken, NJ 08109 | Fax: | 856-616-9519 |
| Send Report To: | Tom Pruno | Send Results To: | sa@editesting.com tp@editesting.com |
| State Samples Taken: | NJ | Turnaround (TAT): | 2 Weeks |

| Matrix | Method | Instrument | Reporting Limit | Preservative |
|---------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------|------------|-----------------------|----------------|
| Drinking Water (Preserved w/HNO ₃ pH <2) | EPA 200.8 | ICP-MS | 0.001 mg/L (ppm) | Nitric acid |
| EDI Client/Site: | Teaneck Public Schools – Central Administration Office | | EDI Project #: | PR-211214-1912 |
| Special Instructions: ** Please provide Excel Data File as well as Standard Report ** | | | | |
| Email Results to: tp@editesting.com / sa@editesting.com | | | | |

| Sample # | Sample Description/Location | Volume | Date/Time Sampled |
|--------------------------------|-----------------------------|---------------------|-------------------------------|
| 39-0505-CA01 | WF between Rms 1 & 2 | 250 mL | 7:07 AM 05/05/2022 |
| 39-0505-CA02 | Deionized Blank | 250 mL | 05/05/2022 |
| Relinquished By: | <i>Melanie Hughes</i> | Received By: | <i>Eduy WJ 5/5/22 10:50am</i> |
| Date: 5/5/22 | Time: <i>1045</i> | Date: | Time: |
| Sampler: Sierra Acevedo | Total Samples: 2 | Page: 1 | of 1 |

*Rec. presence - Blank -
HWS ADDED 5/5 @ 11:00am EL*

2a



EDI is a Service Disabled Veteran Owned Small Business!



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Tom Pruno
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

5/20/2022

Phone: (856) 616-9516

Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/5/2022. The results are tabulated on the attached data pages for the following client designated project:

Teaneck Public Schools - Central Administration Office / Project
#: PR-211214-1912

The reference number for these samples is EMSL Order #012207276. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012207276

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 5/5/2022 10:50 AM

Project: Teaneck Public Schools - Central Administration Office / Project #: PR-211214-1912

Analytical Results

Client Sample Description 39-0505-CA01 **Collected:** 5/5/2022 **Lab ID:** 012207276-0001
 WF Between Rms 1 & 2 7:07:00 AM

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 5/17/2022 KG | 5/18/2022 VD 22:35 |

Client Sample Description 39-0505-CA02 **Collected:** 5/5/2022 **Lab ID:** 012207276-0002
 Deionized Blank

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 5/17/2022 KG | 5/18/2022 VD 22:43 |

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results