

2021-2022 Results Summary Lead in Water Results

School Name: Theodora Smiley Lacey School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
1S	39-0502-ST01	Kitchen 106C - Sink	ND	No
2BB	39-0502-ST02	Room 114 - Bubblers	ND	No
3S	39-0502-ST03	Room 114 - Sink	ND	No
4BB	39-0502-ST04	Room 115 - Bubblers	ND	No
5S	39-0502-ST05	Room 115 - Sink	ND	No
6S	39-0502-ST06	Room 116 - Sink	ND	No
7BB	39-0502-ST07	Room 116 - Bubblers	ND	No
8BB	39-0502-ST08	Room 117 - Bubblers	ND	No
9S	39-0502-ST09	Room 117 - Sink	ND	No
10S	39-0502-ST10	Child Study Room 103 - Sink	ND	No
11BB	39-0502-ST11	Child Study Room 103 - Bubblers	ND	No
12BB	39-0502-ST12	Nurse's Office - Bubblers	ND	No
13S	39-0502-ST13	Nurse's Office - Sink	ND	No
14BB	39-0502-ST14	WF/ Filling station at Main Entrance - Bubblers	ND	No
15BF	39-0502-ST15	WF/ Filling station at Main Entrance - Filler	ND	No
16BB	39-0502-ST16	WF/ Filling station in 1st Floor Hallway - Bubblers	ND	No
17BF	39-0502-ST17	WF/ Filling station in 1st Floor Hallway - Filler	ND	No
18S	39-0502-ST18	Faculty Room 203 - Left tap	7.30	No
19S	39-0502-ST19	Faculty Room 203 - Right small tap	3.71	No
20BB	39-0502-ST20	Room 205 - Bubblers	ND	No

Action Level (AL) \geq 15.5 parts per billion (ppb)



Environmental Design Inc.

Professional Environmental Consultants

Lead (Pb) in Water Sampling Chain of Custody

EMSL Order ID (Lab Use Only): 012207022

Company:	Environmental Design Inc. (EDI-50)	EMSL Bill To:	EDI-50
Street:	5434 King Avenue, Suite 101	Phone:	856-616-9516
City/State/Zip:	Pennsauken, NJ 08109	Fax:	856-616-9519
Send Report To:	Tom Pruno	Send Results To:	tp@editesting.com/ mh@editesting.com
State Samples Taken:	NJ	Turnaround Time (TAT):	2 Weeks

Matrix	Method	Instrument	Reporting Limit	Preservative
Drinking Water (Preserved w/HNO ₃ pH <2)	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	Nitric acid

EDI Client/Site: Teaneck Public Schools – Smiley Theodora Lacey School **EDI Project #:** PR-211214-1912

Special Instructions: ** Please provide Excel Data File as well as Standard Report **

Email Results to: [tp@editesting.com/](mailto:tp@editesting.com) mh@editesting.com

Sample #	Sample Description/Location	Volume	Date/Time Sampled
① 39-0502-ST01	Kitchen 106C - Sink	250 mL	5/2/2022 11:19 AM
② 39-0502-ST02	Room 114 - Bubblers	250 mL	5/2/2022 11:22 AM
③ 39-0502-ST03	Room 114 - Sink	250 mL	5/2/2022 11:24 AM
④ 39-0502-ST04	Room 115 - Bubblers	250 mL	5/2/2022 11:24 AM
⑤ 39-0502-ST05	Room 115 - Sink	250 mL	5/2/2022 11:25 AM
⑥ 39-0502-ST06	Room 116 - Sink	250 mL	5/2/2022 11:26 AM
⑦ 39-0502-ST07	Room 116 - Bubblers	250 mL	5/2/2022 11:27 AM
⑧ 39-0502-ST08	Room 117 - Bubblers	250 mL	5/2/2022 11:26 AM
⑨ 39-0502-ST09	Room 117 - Sink	250 mL	5/2/2022 11:27 AM
⑩ 39-0502-ST10	Child Study Room 103 - Sink	250 mL	5/2/2022 11:30 AM
⑪ 39-0502-ST11	Child Study Room 103 - Bubblers	250 mL	5/2/2022 11:31 AM
⑫ 39-0502-ST12	Nurse's Office - Bubblers	250 mL	5/2/2022 11:29 AM

Relinquished By: <i>Melanie Hughes</i>	Received By: <i>[Signature]</i>
Date: 5/3/22	Date: <i>5/3/22</i>
Time:	Time: <i>12:55</i>
Sampler: Sierra Acevedo	Total Samples: 30 Page: 1 of 3



Edlyn 5/3/22 12:55
EDI is a Service Disabled Veteran Owned Small Business!

Rev. present Et, Blank page. HNO3 ADDED 5/3 @ 13:45 EL



Environmental Design Inc.

Professional Environmental Consultants

Lead (Pb) in Water Sampling Chain of Custody

EMSL Order ID (Lab Use Only): 012207022

Company:	Environmental Design Inc. (EDI-50)	EMSL Bill To:	EDI-50
Street:	5434 King Avenue, Suite 101	Phone:	856-616-9516
City/State/Zip:	Pennsauken, NJ 08109	Fax:	856-616-9519
Send Report To:	Tom Pruno	Send Results To:	tp@editesting.com/ mh@editesting.com
State Samples Taken:	NJ	Turnaround Time (TAT):	2 Weeks

Matrix	Method	Instrument	Reporting Limit	Preservative
Drinking Water (Preserved w/HNO ₃ pH <2)	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	Nitric acid

EDI Client/Site: Teaneck Public Schools – Smiley Theodora Lacey School **EDI Project #:** PR-211214-1912

Special Instructions: ** Please provide Excel Data File as well as Standard Report **

Email Results to: [tp@editesting.com/](mailto:tp@editesting.com) mh@editesting.com

Sample #	Sample Description/Location	Volume	Date/Time Sampled
13 39-0502-ST13	Nurse's Office - Sink	250 mL	5/2/2022 11:30 AM
14 39-0502-ST14	WF/ Filling station at Main Entrance - Bubblers	250 mL	5/2/2022 11:32 AM
15 39-0502-ST15	WF/ Filling station at Main Entrance - Filler	250 mL	5/2/2022 11:33 AM
16 39-0502-ST16	WF/ Filling station in 1st Floor Hallway - Bubblers	250 mL	5/2/2022 11:35 AM
17 39-0502-ST17	WF/ Filling station in 1st Floor Hallway - Filler	250 mL	5/2/2022 11:36 AM
18 39-0502-ST18	Faculty Room - Left tap	250 mL	5/2/2022 11:37 AM
19 39-0502-ST19	Faculty Room - Right small tap	250 mL	5/2/2022 11:38 AM
20 39-0502-ST20	Room 205 - Bubblers	250 mL	5/2/2022 11:37 AM
21 39-0502-ST21	Room 205 - Sink	250 mL	5/2/2022 11:38 AM
22 39-0502-ST22	Room 206 - Sink	250 mL	5/2/2022 11:39 AM
23 39-0502-ST23	Room 206 - Bubblers	250 mL	5/2/2022 11:40 AM
24 39-0502-ST24	Room 207 - Sink	250 mL	5/2/2022 11:41 AM

Relinquished By: <i>Melanie Hughes</i>	Received By:		
Date: 5/3/22	Time:	Date:	Time:
Sampler: Sierra Acevedo	Total Samples: 30	Page: 2	of 3



EDI is a Service Disabled Veteran Owned Small Business!



Environmental Design Inc.

Professional Environmental Consultants

Lead (Pb) in Water Sampling Chain of Custody

EMSL Order ID (Lab Use Only): 012207022

Company:	Environmental Design Inc. (EDI-50)	EMSL Bill To:	EDI-50
Street:	5434 King Avenue, Suite 101	Phone:	856-616-9516
City/State/Zip:	Pennsauken, NJ 08109	Fax:	856-616-9519
Send Report To:	Tom Pruno	Send Results To:	tp@editesting.com/ mh@editesting.com
State Samples Taken:	NJ	Turnaround Time (TAT):	2 Weeks

Matrix	Method	Instrument	Reporting Limit	Preservative
Drinking Water (Preserved w/HNO ₃ pH <2)	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	Nitric acid

EDI Client/Site: Teaneck Public Schools – Smiley Theodora Lacey School **EDI Project #:** PR-211214-1912

Special Instructions: ** Please provide Excel Data File as well as Standard Report **

Email Results to: [tp@editesting.com/](mailto:tp@editesting.com) mh@editesting.com

(25)
(26)
(27)
(28)
(29)
(30)

Sample #	Sample Description/Location	Volume	Date/Time Sampled
39-0502-ST25	Room 207 - Bubblers	250 mL	5/2/2022 11:40 AM
39-0502-ST26	Room 208 - Sink	250 mL	5/2/2022 11:42 AM
39-0502-ST27	Room 208 - Bubblers	250 mL	5/2/2022 11:43 AM
39-0502-ST28	WF/ Filling station in 2nd Floor Hallway - Bubblers	250 mL	5/2/2022 11:40 AM
39-0502-ST29	WF/ Filling station in 2nd Floor Hallway - Sink	250 mL	5/2/2022 11:41 AM
39-0502-ST30	Field Blank	250 mL	
<i>MA 5-3-22</i>			

Relinquished By: <i>Melanie Hughes</i>	Received By:		
Date: 5/3/22	Time:	Date:	Time:
Sampler: Sierra Acevedo	Total Samples: 30	Page: 3	of 3



EDI is a Service Disabled Veteran Owned Small Business!



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Tom Pruno
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

5/19/2022

Phone: (856) 616-9516

Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/3/2022. The results are tabulated on the attached data pages for the following client designated project:

Teaneck Public Schools - Smiley Theodora Lacey School /
Project #: PR-211214-1912

The reference number for these samples is EMSL Order #012207022. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012207022

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 5/3/2022 12:55 PM

Project: Teaneck Public Schools - Smiley Theodora Lacey School / Project #: PR-211214-1912

Analytical Results

Client Sample Description 39-0502-ST01
 Kitchen 106C - Sink
Collected: 5/2/2022 11:19:00 AM
Lab ID: 012207022-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:03

Client Sample Description 39-0502-ST02
 Room 114 - Bubblers
Collected: 5/2/2022 11:22:00 AM
Lab ID: 012207022-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:11

Client Sample Description 39-0502-ST03
 Room 114 - Sink
Collected: 5/2/2022 11:24:00 AM
Lab ID: 012207022-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:12

Client Sample Description 39-0502-ST04
 Room 115 - Bubblers
Collected: 5/2/2022 11:24:00 AM
Lab ID: 012207022-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:14

Client Sample Description 39-0502-ST05
 Room 115 - Sink
Collected: 5/2/2022 11:25:00 AM
Lab ID: 012207022-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:15

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012207022

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 5/3/2022 12:55 PM

Project: Teaneck Public Schools - Smiley Theodora Lacey School / Project #: PR-211214-1912

Analytical Results

Client Sample Description 39-0502-ST06
Room 116 Sink
Collected: 5/2/2022 11:26:00 AM
Lab ID: 012207022-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:17

Client Sample Description 39-0502-ST07
Room 116 - Bubblers
Collected: 5/2/2022 11:27:00 AM
Lab ID: 012207022-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:18

Client Sample Description 39-0502-ST08
Room 117 - Bubblers
Collected: 5/2/2022 11:26:00 AM
Lab ID: 012207022-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:20

Client Sample Description 39-0502-ST09
Room 117 - Sink
Collected: 5/2/2022 11:27:00 AM
Lab ID: 012207022-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:22

Client Sample Description 39-0502-ST10
Child Study Room 103 - Sink
Collected: 5/2/2022 11:30:00 AM
Lab ID: 012207022-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:23

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012207022

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 5/3/2022 12:55 PM

Project: Teaneck Public Schools - Smiley Theodora Lacey School / Project #: PR-211214-1912

Analytical Results

Client Sample Description 39-0502-ST11
 Child Study Room 103 - Bubblers
Collected: 5/2/2022 11:31:00 AM
Lab ID: 012207022-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:25

Client Sample Description 39-0502-ST12
 Nurse's Office - Bubblers
Collected: 5/2/2022 11:29:00 AM
Lab ID: 012207022-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:32

Client Sample Description 39-0502-ST13
 Nurse's Office - Sink
Collected: 5/2/2022 11:30:00 AM
Lab ID: 012207022-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:34

Client Sample Description 39-0502-ST14
 WF/ Filling Station at Main Entrance - Bubblers
Collected: 5/2/2022 11:32:00 AM
Lab ID: 012207022-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:36

Client Sample Description 39-0502-ST15
 WF/ Filling Station at Main Entrance - Filler
Collected: 5/2/2022 11:33:00 AM
Lab ID: 012207022-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:37

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012207022

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 5/3/2022 12:55 PM

Project: Teaneck Public Schools - Smiley Theodora Lacey School / Project #: PR-211214-1912

Analytical Results

Client Sample Description 39-0502-ST16
 WF/ Filling Station in 1st Floor Hallway - Bubblers
Collected: 5/2/2022 11:35:00 AM
Lab ID: 012207022-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:39

Client Sample Description 39-0502-ST17
 WF/ Filling Station in 1st Floor Hallway - Filler
Collected: 5/2/2022 11:36:00 AM
Lab ID: 012207022-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:40

Client Sample Description 39-0502-ST18
 Faculty Room - Left Tap
Collected: 5/2/2022 11:37:00 AM
Lab ID: 012207022-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.30	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:42

Client Sample Description 39-0502-ST19
 Faculty Room - Right Small Tap
Collected: 5/2/2022 11:38:00 AM
Lab ID: 012207022-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.71	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:43

Client Sample Description 39-0502-ST20
 Room 205 - Bubblers
Collected: 5/2/2022 11:37:00 AM
Lab ID: 012207022-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 20:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012207022

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 5/3/2022 12:55 PM

Project: Teaneck Public Schools - Smiley Theodora Lacey School / Project #: PR-211214-1912

Analytical Results

Client Sample Description 39-0502-ST21
 Room 205 - Sink
Collected: 5/2/2022 11:38:00 AM
Lab ID: 012207022-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 19:20

Client Sample Description 39-0502-ST22
 Room 206 - Sink
Collected: 5/2/2022 11:39:00 AM
Lab ID: 012207022-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 19:24

Client Sample Description 39-0502-ST23
 Room 206 - Bubblers
Collected: 5/2/2022 11:40:00 AM
Lab ID: 012207022-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 19:26

Client Sample Description 39-0502-ST24
 Room 207 - Sink
Collected: 5/2/2022 11:41:00 AM
Lab ID: 012207022-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 19:27

Client Sample Description 39-0502-ST25
 Room 207 - Bubblers
Collected: 5/2/2022 11:40:00 AM
Lab ID: 012207022-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 19:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012207022
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 5/3/2022 12:55 PM

Project: Teaneck Public Schools - Smiley Theodora Lacey School / Project #: PR-211214-1912

Analytical Results

Client Sample Description 39-0502-ST26
 Room 208 - Sink
Collected: 5/2/2022 11:42:00 AM
Lab ID: 012207022-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 19:34

Client Sample Description 39-0502-ST27
 Room 208 - Bubblers
Collected: 5/2/2022 11:43:00 AM
Lab ID: 012207022-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 19:35

Client Sample Description 39-0502-ST28
 WF/ Filling Station in 2nd Floor Hallway - Bubblers
Collected: 5/2/2022 11:40:00 AM
Lab ID: 012207022-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 19:37

Client Sample Description 39-0502-ST29
 WF/ Filling Station in 2nd Floor Hallway - Sink
Collected: 5/2/2022 11:41:00 AM
Lab ID: 012207022-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 19:38

Client Sample Description 39-0502-ST30
 Field Blank
Collected: 5/2/2022
Lab ID: 012207022-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/16/2022 VD	5/17/2022 VD 19:40



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

EMSL Order:	012207022
CustomerID:	EDI50
CustomerPO:	
ProjectID:	

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results